



# Vernon Fire Department

## Fireworks Stand Inspection Checklist

Organization Name \_\_\_\_\_ Stand Address \_\_\_\_\_

Inspector Name \_\_\_\_\_ Date \_\_\_\_\_

- | Yes                      | No                       |   |
|--------------------------|--------------------------|---|
| <input type="checkbox"/> | <input type="checkbox"/> | Fireworks stand is a minimum of 5' to any sidewalk or 15' from curbing where no sidewalk exists       |
| <input type="checkbox"/> | <input type="checkbox"/> | Stand is at least 25' from any other building   |
| <input type="checkbox"/> | <input type="checkbox"/> | Stand is at least 100' from any location where flammable liquids are stored or dispensed              |
| <input type="checkbox"/> | <input type="checkbox"/> | No vehicle parking within 10' of stand; vehicles used for sleeping shall be parked 25' from stand     |
| <input type="checkbox"/> | <input type="checkbox"/> | Is graffiti present on stand; if so, remove within 24 hours   |
| <input type="checkbox"/> | <input type="checkbox"/> | Signs posted on stand stating, "No Smoking"   |
| <input type="checkbox"/> | <input type="checkbox"/> | Signs posted on stand stating, "No Sales to Anyone under 16 Years of Age"                             |
| <input type="checkbox"/> | <input type="checkbox"/> | If used, a temporary power pole has been permitted, inspected & approved by the City of Vernon        |
| <input type="checkbox"/> | <input type="checkbox"/> | If used, a portable generator is located at least 25' from stand & all extension cords are heavy duty |
| <input type="checkbox"/> | <input type="checkbox"/> | Extension cords are protected from foot and automobile traffic abrasion                               |
| <input type="checkbox"/> | <input type="checkbox"/> | Weeds and combustible material have been cleared at least 50' of fireworks stand                      |
| <input type="checkbox"/> | <input type="checkbox"/> | Trash container(s) and dumpsters are positioned at least 10' from stand                               |
| <input type="checkbox"/> | <input type="checkbox"/> | 2 or more 2 ½ gallon water-type fire extinguishers are provided in stand and easily visible           |
| <input type="checkbox"/> | <input type="checkbox"/> | Fire extinguishers have been serviced within the last 12 months with inspection tag attached          |
| <input type="checkbox"/> | <input type="checkbox"/> | Fireworks stand aisles and exits are clear of all items; the stand must have at least 2 exits         |
| <input type="checkbox"/> | <input type="checkbox"/> | All fireworks for sale are approved "Safe & Sane" consumer fireworks                                  |
| <input type="checkbox"/> | <input type="checkbox"/> | All licenses and permits are posted in a conspicuous location within the stand                        |