

CITY OF VERNON

RESIDENTIAL AND NON-RESIDENTIAL

CHECKLIST FOR PERMITTING ELECTRIC VEHICLE SERVICE EQUIPMENT (EVSE)

Please complete the following information related to permitting and installation of Electric Vehicle Service Equipment (EVSE) as a supplement to the application for a building permit. This checklist contains the technical aspects of EVSE installations and is intended to help expedite permitting and use for electric vehicle charging.

Upon this checklist being deemed complete, a permit shall be issued to the applicant. However, if it is determined that the installation might have a specific adverse impact on public health or safety, additional verification will be required before a permit can be issued.

This checklist substantially follows the *“Plug-In Electric Vehicle Infrastructure Permitting Checklist”* contained in the *Governor’s Office of Planning and Research “Zero Emission Vehicles in California: Community Readiness Guidebook”* and is purposed to augment the guidebook’s checklist.

Job Address:	Permit No.
<input type="checkbox"/> Single-Family <input type="checkbox"/> Multi-Family (Apartment) <input type="checkbox"/> Commercial (Single Business) <input type="checkbox"/> Commercial (Multi-Businesses)	
Location and Number of EV Charging Stations to be Installed: Garage _____ Parking Level(s) _____ Parking Lot _____	
Description of Work:	

Applicant Name:	
Applicant Phone & email:	
Contractor Name:	License Number & Type:
Contractor Phone & email:	
Owner Name:	
Owner Phone & email:	

EVSE Charging Level: <input type="checkbox"/> Level 1 (120V) <input type="checkbox"/> Level 2 (240V) <input type="checkbox"/> Level 3 (480V) (commercial installations only)	
Nameplate Rating of EV Service Equipment = _____	
Voltage EVSE = _____ V	Manufacturer of EVSE: _____
Mounting of EVSE: <input type="checkbox"/> Wall Mount <input type="checkbox"/> Pole Pedestal Mount <input type="checkbox"/> Other _____	

System Voltage: <input type="checkbox"/> 120/240V, 1 ϕ , 3W <input type="checkbox"/> 120/208V, 3 ϕ , 4W <input type="checkbox"/> 120/240V, 3 ϕ , 4W <input type="checkbox"/> 277/480V, 3 ϕ , 4W <input type="checkbox"/> Other _____
Rating of Existing Main Electrical Service Equipment = _____ Amperes
Rating of Panel Supplying EVSE (if not directly from Main Service) = _____ Amps

Specify Either Connected, Calculated or Documented Demand Load of Existing Panel:

• Connected Load of Existing Panel Supplying EVSE = _____ Amps

• Calculated Load of Existing Panel Supplying EVSE = _____ Amps

• Demand Load of Existing Panel or Service Supplying EVSE = _____ Amps
(Provide Demand Load Reading from Electric Utility)

Total Load (Existing plus EVSE Load) = _____ Amps

EVCS Approval limited to health and safety review

Installation shall comply with Article 625 of the Vernon Electrical Code

EVCS not subject to association approval (if applicable)

EVCS Rating _____ Amps x 1.25 = _____ Amp Minimum Electric Vehicle Branch Circuit Rating

For Single-Family Dwelling : Size of Service Conductors = _____
Size of Feeder Conductor supplying EVSE Panel _____ (if applicable)

I hereby acknowledge that the information presented is a true and correct representation of existing conditions and is subject to field inspection.

Signature of Permit Applicant: _____ Date: _____